

## 2021-2022 Results Summary Lead in Water Results

**School Name: Gloucester City High School**

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
1S	58-0312-GHS-01	Kitchen; Double sink adj. window, right faucet	16.3	Yes
2S	58-0312-GHS-02	Kitchen; Double sink adj .window, left faucet	2.39	No
3S	58-0312-GHS-03	Kitchen; Counter sink, east side	ND	No
4S	58-0312-GHS-04	Kitchen; Counter sink, west side	1.13	No
5S	58-0312-GHS-05	Kitchen; Single sink adj. window	2.69	No
6S	58-0312-GHS-06	Water fountain across from Cafeteria, left	ND	No
7S	58-0312-GHS-07	Water fountain across from Cafeteria, right	ND	No
8WF	58-0312-GHS-08	Girl's Locker Room; Water fountain	ND	No
9WF	58-0312-GHS-09	Old Gym; Water fountain adj. Girl's Locker Room	ND	No
10S	58-0312-GHS-10	Trainer Office; Ice Machine	ND	No
11S	58-0312-GHS-11	Trainer Office; Water bottle sink	ND	No
12WF	58-0312-GHS-12	C-Wing water fountain; left side	ND	No
13WF	58-0312-GHS-13	C-Wing water fountain; right side	ND	No
14WF	58-0312-GHS-14	Water fountain outside New Gym; left	ND	No
15S	58-0312-GHS-15	Water fountain outside New Gym; right	ND	No
16S	58-0312-GHS-16	New Gym lobby; Water fountain, right	ND	No
17S	58-0312-GHS-17	New Gym lobby; Water fountain, right	ND	No
18S	58-0312-GHS-18	B-Wing, north end; Water fountain, right	ND	No
19S	58-0312-GHS-19	B-Wing, north end; Water fountain, left	ND	No
20S	58-0312-GHS-20	B-Wing, south end; Water fountain, right	ND	No

Action Level (AL) ≥15.5 parts per billion (ppb)

## 2021-2022 Results Summary Lead in Water Results

School Name: Gloucester City High School

Outlet Code	Sample ID	Location/Description	Result (ppb)	Above AL?
21S	58-0312-GHS-21	B-Wing, south end; Water fountain, left	ND	No
22I	58-0312-GHS-22	Room D-14; Ice machine	2.51	No
23S	58-0312-GHS-23	A-Wing adj. Room A-19; Water fountain, right	ND	No
24WF	58-0312-GHS-24	A-Wing adj. Room A-19; Water fountain, left	ND	No
25WF	58-0312-GHS-25	Auditorium Lobby; Water fountain, right	ND	No
26S	58-0312-GHS-26	Auditorium Lobby; Water fountain, left	ND	No
27S	58-0312-GHS-27	DI water blank	ND	No

Action Level (AL)  $\geq$ 15.5 parts per billion (ppb)

REVISED



# Environmental Design Inc.

Professional Environmental Consultants

## Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only): 012204116

<b>Company:</b>	Environmental Design Inc. (EDI-50)	<b>EMSL Bill To:</b>	EDI-50
<b>Street:</b>	5434 King Avenue, Suite 101	<b>Phone:</b>	856-616-9516
<b>City/State/Zip:</b>	Pennsauken, NJ 08109	<b>Fax:</b>	856-616-9519
<b>Send Report To:</b>	Tom Pruno	<b>Send Results To:</b>	tp@editesting.com
<b>State Samples Taken:</b>	NJ	<b>Turnaround Time (TAT):</b>	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO <sub>3</sub> pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid

EDI Client/Site: Gloucester City SD – Gloucester City H.S.

EDI Project #: PR-220105-1913

Special Instructions \_\_\_\_\_

Sample #	Sample Description/Location	Volume	Date/Time Sampled
1 58-0312-GHS-01	Kitchen; Double sink adj. window, right faucet	250 mL	3/12/22 10:08 AM 62.6 °F 44.3% rH
2 58-0312-GHS-02	Kitchen; Double sink adj .window, left faucet	250 mL	3/12/22 10:09 AM 62.4 °F 44.6% rH
3 58-0312-GHS-03	Kitchen; Counter sink, east side	250 mL	3/12/22 10:11 AM 63.9 °F 42.3% rH
4 58-0312-GHS-04	Kitchen; Counter sink, west side	250 mL	3/12/22 10:12 AM 63.6 °F 42.4% rH
5 58-0312-GHS-05	Kitchen; Single sink adj. window	250 mL	3/12/22 10:15 AM 63.8 °F 42.2% rH
6 58-0312-GHS-06	Water fountain across from Cafeteria, left	250 mL	3/12/22 10:22 AM 64.5 °F 42.5% rH
7 58-0312-GHS-07	Water fountain across from Cafeteria, right	250 mL	3/12/22 10:22 AM 64.5 °F 42.5% rH
8 58-0312-GHS-08	Girl's Locker Room; Water fountain	250 mL	3/12/22 10:29 AM 65.2 °F 38.7% rH
9 58-0312-GHS-09	Old Gym; Water fountain adj. Girl's Locker Room	250 mL	3/12/22 10:32 AM 67.0 °F 37.6% rH
10 58-0312-GHS-10	Trainer Office; Ice Machine	250 mL	3/12/22 10:40 AM 66.2 °F 38.4% rH
11 58-0312-GHS-11	Trainer Office; Water bottle sink	250 mL	3/12/22 10:41 AM 66.1 °F 38.6% rH
12 58-0312-GHS-12	C-Wing water fountain; left side	250 mL	3/12/22 10:45 AM 66.1 °F 38.6% rH

<b>Relinquished By:</b>	<i>T. Mulhern</i>	<b>Received By:</b>	<i>CDC RECEIVED VIA EMAIL 3/18/22 1:34p.m. EW</i>		
<b>Date:</b>	3/14/2022	<b>Date:</b>		<b>Time:</b>	
<b>Sampler(s):</b>	T. Mulhern	<b>Total Samples:</b>		<b>Page:</b>	1 of 2



EDI is a Service Disabled Veteran Owned Small Business!

27 EW

# EDI

## Lead (Pb) in Water Sampling Chain of Custody (cont.)

EMSL Order ID (Lab Use Only): 012204116

EDI Client/Site: Gloucester City SD – Gloucester City H.S.

EDI Project #: PR-220105-1913

Sample #	Sample Description/Location	Volume	Date/Time Sampled
13	58-0312-GHS-13 C-Wing water fountain; right side	250 mL	3/12/22 10:45 AM 66.1 °F 38.6% rH
14	58-0312-GHS-14 Water fountain outside New Gym; left	250 mL	3/12/22 10:50 AM 68.8 °F 36.3% rH
15	58-0312-GHS-15 Water fountain outside New Gym; right	250 mL	3/12/22 10:51 AM 68.8 °F 36.3% rH
16	58-0312-GHS-16 New Gym lobby; Water fountain, right	250 mL	3/12/22 10:54 AM 70.6 °F 35.4% rH
17	58-0312-GHS-17 New Gym lobby; Water fountain, right	250 mL	3/12/22 10:55 AM 70.6 °F 35.4% rH
18	58-0312-GHS-18 B-Wing, north end; Water fountain, right	250 mL	3/12/22 11:05 AM 69.3 °F 35.0% rH
19	58-0312-GHS-19 B-Wing, north end; Water fountain, left	250 mL	3/12/22 11:05 AM 69.3 °F 35.0% rH
20	58-0312-GHS-20 B-Wing, south end; Water fountain, right	250 mL	3/12/22 11:09 AM 71.7 °F 32.1% rH
21	58-0312-GHS-21 B-Wing, south end; Water fountain, left	250 mL	3/12/22 11:09 AM 71.7 °F 32.1% rH
22	58-0312-GHS-22 Room D-14; Ice machine	250 mL	3/12/22 11:12 AM 69.4 °F 38.4% rH
23	58-0312-GHS-23 A-Wing adj. Room A-19; Water fountain, right	250 mL	3/12/22 11:15 AM 68.2 °F 33.3% rH
24	58-0312-GHS-24 A-Wing adj. Room A-19; Water fountain, left	250 mL	3/12/22 11:16 AM 68.2 °F 33.3% rH
25	58-0312-GHS-25 Auditorium Lobby; Water fountain, right	250 mL	3/12/22 11:21 AM 68.8 °F 37.6% rH
26	58-0312-GHS-26 Auditorium Lobby; Water fountain, left	250 mL	3/12/22 11:22 AM 68.8 °F 37.6% rH
27	58-0312-GHS-27 DI water blank	250 mL	N/A

Drinking Water (preserved w/HNO3 pH <2); Method EPA 200.8; ICP-MS; Reporting Limit 0.001 mg/L (ppm)

Page: 2 of 2



EDI is a Service Disabled Veteran Owned Small Business!



# Environmental Design Inc.

Professional Environmental Consultants

## Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only): 012204116

<b>Company:</b>	Environmental Design Inc. (EDI-50)	<b>EMSL Bill To:</b>	EDI-50
<b>Street:</b>	5434 King Avenue, Suite 101	<b>Phone:</b>	856-616-9516
<b>City/State/Zip:</b>	Pennsauken, NJ 08109	<b>Fax:</b>	856-616-9519
<b>Send Report To:</b>	Tom Pruno	<b>Send Results To:</b>	tp@editesting.com
<b>State Samples Taken:</b>	NJ	<b>Turnaround Time (TAT):</b>	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO <sub>3</sub> pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid

EDI Client/Site: Gloucester City SD – Gloucester City H.S.

EDI Project #: PR-220105-1913

**Special Instructions**

Sample #	Sample Description/Location	Volume	Date/Time Sampled
1	58-0312-GHS-01 Kitchen; Double sink adj. window, right faucet	250 mL	3/12/22 10:08 AM 62.6 °F 44.3% rH
2	58-0312-GHS-02 Kitchen; Double sink adj. window, left faucet	250 mL	3/12/22 10:09 AM 62.4 °F 44.6% rH
3	58-0312-GHS-03 Kitchen; Counter sink, east side	250 mL	3/12/22 10:11 AM 63.9 °F 42.3% rH
4	58-0312-GHS-04 Kitchen; Counter sink, west side	250 mL	3/12/22 10:12 AM 63.6 °F 42.4% rH
5	58-0312-GHS-05 Kitchen; Single sink adj. window	250 mL	3/12/22 10:15 AM 63.8 °F 42.2% rH
6	58-0312-GHS-06 Water fountain across from Cafeteria, left	250 mL	3/12/22 10:22 AM 64.5 °F 42.5% rH
7	58-0312-GHS-07 Water fountain across from Cafeteria, right	250 mL	3/12/22 10:22 AM 64.5 °F 42.5% rH
8	58-0312-GHS-08 Girl's Locker Room; Water fountain	250 mL	3/12/22 10:29 AM 65.2 °F 38.7% rH
9	58-0312-GHS-09 Old Gym; Water fountain adj. Girl's Locker Room	250 mL	3/12/22 10:32 AM 67.0 °F 37.6% rH
10	58-0312-GHS-10 Trainer Office; Ice Machine	250 mL	3/12/22 10:40 AM 66.2 °F 38.4% rH
11	58-0312-GHS-11 Trainer Office; Water bottle sink	250 mL	3/12/22 10:41 AM 66.1 °F 38.6% rH
12	58-0312-GHS-12 C-Wing water fountain; left side	250 mL	3/12/22 10:45 AM 66.1 °F 38.6% rH

<b>Relinquished By:</b> <i>[Signature]</i>	<b>Received By:</b> <i>[Signature]</i>
<b>Date:</b> 3/14/2022	<b>Date:</b> 3/14/22
<b>Time:</b> 03:10 PM	<b>Time:</b> 3:12
<b>Sampler(s):</b> T. Mulhern	<b>Total Samples:</b> 26
	<b>Page:</b> 1 of 2



EDI is a Service Disabled Veteran Owned Small Business!

*Chapman 3/14/22 15:12*  
*Rec. Pruno et*  
*Blank - HNO3 ADDED 3/15/22 27:05 am*

27



## Lead (Pb) in Water Sampling Chain of Custody (cont.)

EMSL Order ID (Lab Use Only): 012204116

EDI Client/Site: Gloucester City SD – Gloucester City H.S.

EDI Project #: PR-220105-1913

Sample #	Sample Description/Location	Volume	Date/Time Sampled
13	58-0312-GHS-13 C-Wing water fountain; right side	250 mL	3/12/22 10:45 AM 66.1 °F 38.6% rH
14	58-0312-GHS-14 Water fountain outside New Gym; left	250 mL	3/12/22 10:50 AM 68.8 °F 36.3% rH
15	58-0312-GHS-15 Water fountain outside New Gym; right	250 mL	3/12/22 10:51 AM 68.8 °F 36.3% rH
16	58-0312-GHS-16 New Gym lobby; Water fountain, right	250 mL	3/12/22 10:54 AM 70.6 °F 35.4% rH
17	58-0312-GHS-17 New Gym lobby; Water fountain, right	250 mL	3/12/22 10:55 AM 70.6 °F 35.4% rH
18	58-0312-GHS-18 B-Wing, north end; Water fountain, right	250 mL	3/12/22 11:05 AM 69.3 °F 35.0% rH
19	58-0312-GHS-19 B-Wing, north end; Water fountain, left	250 mL	3/12/22 11:05 AM 69.3 °F 35.0% rH
20	58-0312-GHS-20 B-Wing, south end; Water fountain, right	250 mL	3/12/22 11:09 AM 71.7 °F 32.1% rH
	58-0312-GHS-22 B-Wing, south end; Water fountain, left	250 mL	3/12/22 11:09 AM 71.7 °F 32.1% rH
	58-0312-GHS-23 A-Wing adj. Room A-19; Water fountain, right	250 mL	3/12/22 11:15 AM 68.2 °F 33.3% rH
	58-0312-GHS-24 A-Wing adj. Room A-19; Water fountain, left	250 mL	3/12/22 11:16 AM 68.2 °F 33.3% rH
	58-0312-GHS-25 Auditorium Lobby; Water fountain, right	250 mL	3/12/22 11:21 AM 68.8 °F 37.6% rH
	58-0312-GHS-26 Auditorium Lobby; Water fountain, left	250 mL	3/12/22 11:22 AM 68.8 °F 37.6% rH
	58-0312-GHS-27 DI water blank	250 mL	N/A

Drinking Water (preserved w/HNO3 pH <2); Method EPA 200.8; ICP-MS; Reporting Limit 0.001 mg/L (ppm)

Page: 2 of 2

SAMPLE # GHS-21 RECEIVED EN 3/17



EDI is a Service Disabled Veteran Owned Small Business!



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

3/28/2022

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 3/14/2022. The results are tabulated on the attached data pages for the following client designated project:

**Gloucester City SD - Gloucester City H.S. / Project #: PR-220105-1913**

The reference number for these samples is EMSL Order #012204116. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012204116  
 CustomerID: EDI50  
 CustomerPO:  
 ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 03/14/22 3:12 PM

Project: Gloucester City SD - Gloucester City H.S. / Project #: PR-220105-1913

**Analytical Results**

**Client Sample Description** 58-0312-GHS-01  
 Kitchen, Double Sink Adj. Window, Right  
 Faucet  
**Collected:** 3/12/2022 10:08:00 AM  
**Lab ID:** 012204116-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	16.3	1.00 µg/L	3/22/2022 VD	03/22/22 22:29 VD

**Client Sample Description** 58-0312-GHS-02  
 Kitchen, Double Sink Adj. Window, Left  
 Faucet  
**Collected:** 3/12/2022 10:09:00 AM  
**Lab ID:** 012204116-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.39	1.00 µg/L	3/22/2022 VD	03/22/22 22:34 VD

**Client Sample Description** 58-0312-GHS-03  
 Kitchen, Counter Sink, East Side  
**Collected:** 3/12/2022 10:11:00 AM  
**Lab ID:** 012204116-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:39 VD

**Client Sample Description** 58-0312-GHS-04  
 Kitchen, Counter Sink, West Side  
**Collected:** 3/12/2022 10:12:00 AM  
**Lab ID:** 012204116-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.13	1.00 µg/L	3/22/2022 VD	03/22/22 22:40 VD

**Client Sample Description** 58-0312-GHS-05  
 Kitchen, Single Sink Adj. Window  
**Collected:** 3/12/2022 10:15:00 AM  
**Lab ID:** 012204116-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	2.69	1.00 µg/L	3/22/2022 VD	03/22/22 22:42 VD



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012204116

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 03/14/22 3:12 PM

Project: Gloucester City SD - Gloucester City H.S. / Project #: PR-220105-1913

**Analytical Results**

**Client Sample Description** 58-0312-GHS-06  
 Water Fountain Across from Cafeteria, Left  
**Collected:** 3/12/2022 10:22:00 AM  
**Lab ID:** 012204116-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:44 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-07  
 Water Fountain Across from Cafeteria, Right  
**Collected:** 3/12/2022 10:22:00 AM  
**Lab ID:** 012204116-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:45 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-08  
 Girl's Locker Room, Water Fountain  
**Collected:** 3/12/2022 10:29:00 AM  
**Lab ID:** 012204116-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:47 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-09  
 Old Gym, Water Fountain Adj. Girl's Locker Room  
**Collected:** 3/12/2022 10:32:00 AM  
**Lab ID:** 012204116-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:48 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-10  
 Trainer Office, Ice Machine  
**Collected:** 3/12/2022 10:40:00 AM  
**Lab ID:** 012204116-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:50 VD
-------	------	----	-----------	--------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012204116

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 03/14/22 3:12 PM

Project: Gloucester City SD - Gloucester City H.S. / Project #: PR-220105-1913

**Analytical Results**

**Client Sample Description** 58-0312-GHS-11  
 Trainer Office, Water Bottle Sink  
**Collected:** 3/12/2022  
 10:41:00 AM  
**Lab ID:** 012204116-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:51 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-12  
 C-Wing Water Fountain, Left Side  
**Collected:** 3/12/2022  
 10:45:00 AM  
**Lab ID:** 012204116-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 22:59 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-13  
 C-Wing Water Fountain, Right Side  
**Collected:** 3/12/2022  
 10:45:00 AM  
**Lab ID:** 012204116-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:01 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-14  
 Water Fountain Outside New Gym, Left  
**Collected:** 3/12/2022  
 10:50:00 AM  
**Lab ID:** 012204116-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:02 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-15  
 Water Fountain Outside New Gym, Right  
**Collected:** 3/12/2022  
 10:51:00 AM  
**Lab ID:** 012204116-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:04 VD
-------	------	----	-----------	--------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order:	012204116
CustomerID:	EDI50
CustomerPO:	
ProjectID:	

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 03/14/22 3:12 PM

Project: Gloucester City SD - Gloucester City H.S. / Project #: PR-220105-1913

**Analytical Results**

**Client Sample Description** 58-0312-GHS-16  
 New Gym Lobby, Water Fountain, Right  
**Collected:** 3/12/2022 10:54:00 AM  
**Lab ID:** 012204116-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:05 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-17  
 New Gym Lobby, Water Fountain, Right  
**Collected:** 3/12/2022 10:55:00 AM  
**Lab ID:** 012204116-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:07 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-18  
 B-Wing, North End, Water Fountain, Right  
**Collected:** 3/12/2022 11:05:00 AM  
**Lab ID:** 012204116-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:09 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-19  
 B-Wing, North End, Water Fountain, Left  
**Collected:** 3/12/2022 11:05:00 AM  
**Lab ID:** 012204116-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:10 VD
-------	------	----	-----------	--------------	-------------------

**Client Sample Description** 58-0312-GHS-20  
 B-Wing, South End, Water Fountain, Right  
**Collected:** 3/12/2022 11:09:00 AM  
**Lab ID:** 012204116-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/22/22 23:12 VD
-------	------	----	-----------	--------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012204116

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 03/14/22 3:12 PM

Project: Gloucester City SD - Gloucester City H.S. / Project #: PR-220105-1913

**Analytical Results**

**Client Sample Description** 58-0312-GHS-21  
 B-Wing, South End, Water Fountain, Left  
**Collected:** 3/12/2022 11:09:00 AM  
**Lab ID:** 012204116-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/23/22 1:01 VD
-------	------	----	-----------	--------------	------------------

**Client Sample Description** 58-0312-GHS-22  
 Room D-14, Ice Machine  
**Collected:** 3/12/2022 11:12:00 AM  
**Lab ID:** 012204116-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	2.51	1.00 µg/L	3/22/2022 VD	03/23/22 1:09 VD
-------	------	------	-----------	--------------	------------------

**Client Sample Description** 58-0312-GHS-23  
 A-Wing Adj. Room A-19, Water Fountain, Right  
**Collected:** 3/12/2022 11:15:00 AM  
**Lab ID:** 012204116-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/23/22 1:11 VD
-------	------	----	-----------	--------------	------------------

**Client Sample Description** 58-0312-GHS-24  
 A-Wing Adj. Room A-19, Water Fountain, Left  
**Collected:** 3/12/2022 11:16:00 AM  
**Lab ID:** 012204116-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/23/22 1:12 VD
-------	------	----	-----------	--------------	------------------

**Client Sample Description** 58-0312-GHS-25  
 Auditorium Lobby, Water Fountain, Right  
**Collected:** 3/12/2022 11:21:00 AM  
**Lab ID:** 012204116-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

**METALS**

200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/23/22 1:14 VD
-------	------	----	-----------	--------------	------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012204116

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**  
**Environmental Design, Inc.**  
**5434 King Avenue**  
**Suite 101**  
**Pennsauken, NJ 08109**

Phone: (856) 616-9516  
 Fax: (586) 616-9517  
 Received: 03/14/22 3:12 PM

Project: Gloucester City SD - Gloucester City H.S. / Project #: PR-220105-1913

**Analytical Results**

**Client Sample Description** 58-0312-GHS-26 **Collected:** 3/12/2022 **Lab ID:** 012204116-0026  
 Auditorium Lobby, Water Fountain, Left 11:22:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/23/22 1:15 VD

**Client Sample Description** 58-0312-GHS-27 **Collected:** 3/12/2022 **Lab ID:** 012204116-0027  
 DI Water Blank

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	3/22/2022 VD	03/23/22 1:17 VD

**Definitions:**

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results